



NOTES :

1. TANK IS DESIGNED AND CONSTRUCTED IN ACCORDANCE WITH U.N. SPECIFICATIONS
2. TANK IS AIR TESTED AT 3 PSI
3. ALL WELDS CLEANED OF SLAG AND SPATTER
4. TANK INTERIOR AND EXTERIOR ARE ELECTRO-CLEANED
5. DRUM LID TO BE INSTALLED BY: STRIKE RING AROUND CIRCUMFERENCE WITH A MALLET THEN TIGHTEN THE BOLT WITH A WRENCH. REPEAT UNTIL BOLT TIGHTENING RESISTANCE DOES NOT CHANGE (REF: 40 LB-FT)
6. 2IN BUNG TO BE INSTALLED 3/8 TO 1/2 ROTATION BEYOND SOLID GASKET CONTACT (REF: 30 LB-FT)

BILL OF MATERIALS



LINCOLN, NE 68504 PHONE:(402) 467-5221 FAX:(402) 467-3247

CUSTOMER	
----------	--

S I I STANDARD

6984500B51324

JOB:

SCALE: NONE

APPROVED BY:

DRAWN BY: L.T

DATE: 11/12/2010

CHECKED BY:

DESCRIPTION:	
--------------	--

550 GAL 42 X 48 SUPERTAINER SS

DRAWING NUMBER:

25514